

# Device Status

Last Modified on 10/13/2022 10:20 am EDT

[stages® Documentation - Home](#)

## **Device Status**

Device Status displays the current state of the [device](#). Device Status is displayed in a tab on the Quick Call and the [Alarm Dispatch](#) windows.

### Tripped Points

Tripped Points returns a list of all points that have been tripped by a signal.

### Off Normal Points

Off Normal Points displays a list of points that require restore. The points can be cleared from the list. This will affect the stages™ database, but not the device itself. The Operator Action 'ClrPtStatus' will be logged to history when the point is cleared.

### Device Status

Device Status lists the Expected Events of the device. This includes Open/Close, Scheduled Device [Tests](#) and Timer Tests. Open/Close signals are set up in the [Schedule](#) window. Timer Tests are setup in the Device window. The next timer test can be scheduled with the Set button. When Expected Events for Schedule and Timer Tests are met, the next expected event is set up automatically. When a Open is logged, the Close is expected at the scheduled time. When a Close is logged, the Open is expected at the next scheduled time. When a Timer Test signal is met, it is rescheduled according to the timer test hours, minutes set on the Device.

### Area Status

Area Status displays the armed/disarmed status of the areas configured for the device. The status can be manually switched between armed/disarmed.